

ERNIE FLETCHER
GOVERNOR



TERESA J. HILL
SECRETARY

TIM LEDONNE
COMMISSIONER

ENVIRONMENTAL AND PUBLIC PROTECTION CABINET
DEPARTMENT OF PUBLIC PROTECTION
OFFICE OF HOUSING, BUILDINGS AND CONSTRUCTION
DIVISION OF PLUMBING
TIM HOUSE, DIVISION DIRECTOR
101 SEA HERO ROAD, SUITE 100
FRANKFORT, KENTUCKY 40601-5405
TELEPHONE: (502) 573-0397
FAX: (502) 573-1058
WEB SITE: WWW.OHBC.KY.GOV

September 11, 2007

Eric,

Below is the regulation and subsection that the Schluter Shower System is currently listed in the Approved Parts or Material list of the code.

Please keep in mind that your current drain body due to being of PVC material is limited to projects that do not exceed the 45 feet stack height. At the time that you do have metallic drain bodies provide that information to our office for further approval. Depending on the design of the drain, approval by the Office may be sufficient.

You can find your listing online at <http://www.lrc.ky.gov/kar/815/020/020.htm>

815 KAR 20:020. Parts or materials list.

(59) Schluter Shower System for waterproofing tiled shower installations installed per manufacturer recommendations.

If you have any other questions feel free to let me know,

Tim House